

REPORT

TOWN OF VICTOR ZONING BOARD OF APPEALS

July 5, 2016 – 7:00 p.m.
Town of Victor Town Hall, 85 E. Main St. Victor, NY 14564

PUBLIC HEARING

1. SABIC SHED - SPRINKLER WAIVER
7036 Dryer Road
Appl. No. 14-Z-2016

**APPROVED – THE
REQUIREMENT FOR THE
SPRINKLER SYSTEM HAS BEEN
WAIVED**

Applicant is building a 12' x 16' shed to store tools. Section 83-4F(2)(a) states that all structures, except those structures set forth in subsection F(2)(c) shall be required to have an approved fire sprinkler system.

Information and plans available for review at the Planning & Building Office located at 85 East Main Street. All public are welcome to attend meetings. Written comments may be directed to planning@town-victor-ny.us or mail to Planning at 85 East Main St., Victor, NY 14564 prior to meeting. For additional information call 585-742-5040.